## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No. 7135-0026:205 Page 1 of 1

CATEGORY: **Audible Devices** 

LISTEE: Simplex, \*100 Simplex Drive, Westminster, MA 01441-0001

Contact: Paul Mattern (978) 731-8542

DESIGN: Models 4098-9782 and 4098-9786 detector bases with an integral audible device. The

> audible device is suitable for fire protective signaling service. It also requires separate 24 VDC power. Refer to listee's data sheet for detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/audibility rating and UL label.

APPROVAL: Listed as audible device for use with Model 4100 MAPNET II (CSFM Listing No. 7165-

> 0026:160 and 7170-0026:187) or Model 2120 MAPNET II (CSFM Listing No. 7170-0026:125 and 7165-0026:126) or Model 4020-8001 (CSFM Listing No. 7165-0026:178)

control units.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

MAY 4, 2001 Date Issued: Listing Expires June 30, 2002

**BEN HO**, Supervising Deputy Authorized By:

Program Manager